

Test report - ELP32P3D

Object of test: Three-phase electric squirrel-cage motor
Kind of test: Determination of efficiency acc. To CSA C390-10 - clause 5.1
Test report no: 263/I/10

Frame: 182T

Type: ELP

Serial no: AB116063

MOTOR DESCRIPTION:

Manufacturer: US Motors / FME Indukta S.A.
Rated power: 1.5 [Hp]
Number of poles: 6
Rated voltage: 460 [V]
Rated current: 2.4 [A]
Speed: 1170 [RPM]
Frequency: 60 [Hz]
Power factor: 0.68 [-]
Nominal efficiency "f": 87.5 [%]
Number of phases: 3
Time rating: S1
Service factor: 1.4
NEMA design: B
KVA code: J
Insulation class: F
Max. amb. temperature: 40 [°C]

TESTING SCHEDULE

- 1) Winding resistance measurements (clause 7.1.2)
- 2) Heat-run test for S.F 1.0 (clause 7.1.3)
- 3) Load test (clause 7.1.4)
- 4) No-load test. (clause 7.1.7)
- 5) Determination of efficiency (clause 7.2.6)

Test report - ELP32P3D

Frame: 182T

Type: ELP

Serial no: AB116063

A.7.1.2 Temperature measurement

Cold winding temperature, $t_{det\ cold}$ (°C) 35.5
Cold stator winding resistance, R_{cold} (W) 7.62169

A.7.1.3 Heat-run test

Stator winding resistance, R_{hr} (W) 8.12264
Stator winding temperature, $t_{res\ hr}$ (°C) 53.2
Ambient temperature, $t_{amb\ hr}$ (°C) 35

A.7.1.4 Load test

% of full load
Torque output, T_{lt} (i), (Nm)
Power input, $P_{in\ lt}$ (i), (kW)
each line current, I_a lt(i), I_b lt(i), I_c lt(i) (A)
Rotational speed, n_{lt} (i), (RPM)
Stator winding temperature, $t_{det\ lt}$ (i), (°C)
Ambient temperature, $t_{amb\ lt}$ (i), (°C)
each line-to-line voltage, V_{a-b} lt(i), V_{b-c} lt(i), V_{c-a} lt(i) (V)
Frequency, f_{lt} (i), (Hz)

143	125	101	75	47	18
13.07	11.38	9.18	6.90	4.29	1.66
1.8363	1.5936	1.2919	0.9817	0.6317	0.294
3.065	2.678	2.378	2.071	1.768	1.593
1157.1	1163.3	1172.1	1179.0	1187.3	1195.4
53.4	53.6	53.6	53.4	53.1	52.5
35.0	35.0	35.0	35.0	35.0	35.0
460.40	460.61	460.49	460.52	459.29	459.77
60.01	60.01	59.99	59.99	60.00	60.00
No	Tdyno cf, (Nm)				0
13.07	11.38	9.18	6.90	4.29	1.66

A.7.1.5 Dynamometer correction test

$T_{lt\ corr} =$

A.7.1.7 No-Load test

% of nominal voltage,
each line-to-line voltage, V_{a-b} lt(i), V_{b-c} lt(i), V_{c-a} lt(i) (V)
each line current, I_a lt(i), I_b lt(i), I_c lt(i) (A)
(c) power input, $P_{in\ nl}$ (i), (kW)
(d-1) stator winding temperature, $t_{det\ nl}$ (i), (°C)
(h) frequency, f_{nl} (i), (Hz)

105	100	95	50	35	24
483.47	460.32	437.20	229.65	159.59	112.11
1.698	1.563	1.443	0.661	0.451	0.323
0.09447	0.08471	0.07662	0.027148	0.017533	0.01266
48	48	47.9	47.7	47.5	47.2
60.01	59.99	60.00	60.00	60.01	60.00

A 7.2 Calculation

% of full load
Power output corrected, $P_{corr\ out\ lt}$ (i), (HP)
Power output corrected, $P_{corr\ out\ lt}$ (i), (kW)
Line current, $I_{avg\ lt}$ (i) (A)
Slip per unit corrected, $S_{corr\ lt}$ (i)
Power input, $P_{in\ lt}$ (i), (kW)
Core loss, P_{core} (i), (kW)
Windage-friction loss $P_{wind-frict}$ (kW)
Stray-load losses, $P_{stray-load\ lt}$ (i) (kW)
Stator winding correction, $P_{corr\ stator\ lt}$ (i) (kW)
Rotor winding correction, $P_{corr\ rotor\ lt}$ (i) (kW)
Power Factor, $PF\ lt$ (i), (%)
Efficiency, $Eff\ lt$ (i), (%)

130	115	100	75	50	25
1.95	1.73	1.50	1.13	0.75	0.38
1.46	1.29	1.12	0.84	0.56	0.28
3.07	2.68	2.38	2.07	1.77	1.59
0.0345	0.0296	0.0222	0.0167	0.0102	0.0037
1.836	1.594	1.292	0.982	0.632	0.294
0.045	0.045	0.045	0.046	0.046	0.047
0.008	0.008	0.008	0.008	0.008	0.008
0.027	0.021	0.013	0.008	0.003	0.000
0.110	0.084	0.067	0.050	0.037	0.030
0.058	0.043	0.026	0.015	0.006	0.001
75.131	74.580	68.114	59.441	44.922	23.179
86.462	87.359	87.638	87.082	84.234	70.749
$\gamma =$					0.987

Summary: Parameters of tested motor are in compliance with requirements.

Date of testing: 16-Jul-11

Measurements made by:	D Formas	M Ptaszkis	G Tlałka
Test Report written by:	T Dobosz	Approved by:	A Opitek

Appendices:

1) List of measurement instruments used in tests.