

Test report - ELP3P2D

Object of test: Three-phase electric squirrel-cage motor
Kind of test: Determination of efficiency acc. To CSA C390-10 - clause 5.1
Test report no: 138/I/11

Frame: 213T

Type: ELP

Serial no: AC064614

MOTOR DESCRIPTION:

Manufacturer: US Motors / FME Indukta S.A.
Rated power: 3 [Hp]
Number of poles: 6
Rated voltage: 460 [V]
Rated current: 4.2 [A]
Speed: 1165 [RPM]
Frequency: 60 [Hz]
Power factor: 0.74 [-]
Nominal efficiency" η ": 89.5 [%]
Number of phases: 3
Time rating: S1
Service factor: 1.4
NEMA design: B
KVA code: K
Insulation class: F
Max. amb. temperature: 40 [°C]

TESTING SCHEDULE

- 1) Winding resistance measurements (clause 7.1.2)
- 2) Heat-run test for S.F 1.0 (clause 7.1.3)
- 3) Load test (clause 7.1.4)
- 4) No-load test. (clause 7.1.7)
- 5) Determination of efficiency (clause 7.2.6)

Test report - ELP3P2D

Frame: 213T

Type: ELP

Serial no: AC064614

A.7.1.2 Temperature measurement

Cold winding temperature, $t_{det\ cold}$ (°C) 23.1
Cold stator winding resistance, R_{cold} (W). 3.16656

A.7.1.3 Heat-run test

Stator winding resistance, R_{hr} (W). 3.41804
Stator winding temperature, $t_{res\ hr}$ (°C) 43.6
Ambient temperature, $t_{amb\ hr}$ (°C) 25.2

A.7.1.4 Load test

% of full load
Torque output, T_{lt} (i), (Nm)
Power input, $P_{in\ lt}$ (i), (kW)
each line current, I_a lt(i), I_b lt(i), I_c lt(i) (A)
Rotational speed, n_{lt} (i), (RPM)
Stator winding temperature, $t_{det\ lt}$ (i), (°C)
Ambient temperature, $t_{amb\ lt}$ (i), (°C)
each line-to-line voltage, V_{a-b} lt(i), V_{b-c} lt(i), V_{c-a} lt(i) (V)
Frequency, f_{lt} (i), (Hz)

141	116	100	74	50	18
25.94	21.27	18.38	13.61	9.18	3.25
3.55077	2.91578	2.52165	1.89059	1.31587	0.55432
5.499	4.719	4.266	3.600	3.092	2.643
1165.0	1172.0	1176.0	1183.0	1189.0	1196.0
45.2	45.3	45	44.6	44	43.4
25.1	25.1	25.1	25.1	25.1	25.1
459.95	460.24	460.20	460.70	460.53	459.52
59.99	60.00	60.00	60.00	60.01	60.01
No	T _{dyno cf} , (Nm)				0
25.94	21.27	18.38	13.61	9.18	3.25

A.7.1.5 Dynamometer correction test

$T_{lt\ corr} =$

A.7.1.7 No-Load test

% of nominal voltage,
each line-to-line voltage, V_{a-b} lt(i), V_{b-c} lt(i), V_{c-a} lt(i) (V)
each line current, I_a lt(i), I_b lt(i), I_c lt(i) (A)
(c) power input, $P_{in\ nl}$ (i), (kW)
(d-1) stator winding temperature, $t_{det\ nl}$ (i), (°C)
(h) frequency, f_{nl} (i), (Hz)

105	100	95	50	35	24
483.65	460.23	437.40	230.16	161.04	111.94
2.745	2.578	2.433	1.229	0.865	0.620
0.15863	0.14342	0.13286	0.05426	0.0382	0.02903
38	38	37.9	37.5	36.9	36.4
60.01	60.01	60.01	60.01	60.02	60.03

A 7.2 Calculation

% of full load
Power output corrected, $P_{corr\ out\ lt}$ (i), (HP)
Power output corrected, $P_{corr\ out\ lt}$ (i), (kW)
Line current, $I_{avg\ lt}$ (i) (A)
Slip per unit corrected, $S_{corr\ lt}$ (i)
Power input, $P_{in\ lt}$ (i), (kW)
Core loss, P_{core} (i), (kW)
Windage-friction loss $P_{wind-frict}$, (kW)
Stray-load losses, $P_{stray-load\ lt}$ (i) (kW)
Stator winding correction, $P_{corr\ stator\ lt}$ (i) (kW)
Rotor winding correction, $P_{corr\ rotor\ lt}$ (i) (kW)
Power Factor, $PF\ lt$ (i), (%)
Efficiency, $Eff\ lt$, (%)

130	115	100	75	50	25
3.90	3.45	3.00	2.25	1.50	0.75
2.91	2.57	2.24	1.68	1.12	0.56
5.50	4.72	4.27	3.60	3.09	2.64
0.0290	0.0232	0.0199	0.0142	0.0093	0.0036
3.551	2.916	2.522	1.891	1.316	0.554
0.084	0.085	0.086	0.086	0.087	0.088
0.021	0.021	0.021	0.021	0.021	0.021
0.029	0.020	0.015	0.008	0.004	0.000
0.155	0.114	0.093	0.066	0.049	0.036
0.096	0.063	0.047	0.025	0.011	0.002
81.047	77.516	74.164	65.819	53.347	26.354
89.139	89.600	89.628	89.052	86.915	73.489
$\gamma =$					0.982

Summary: Parameters of tested motor are in compliance with requirements.

Date of testing: 13-Jun-11

Measurements made by:	D Formas	M Ptazkis	G Tlalka
Test Report written by:	T Dobosz	Approved by:	A Opitek

Appendices:

1) List of measurement instruments used in tests.